

TO BE FILLED BY THE INSPECTING OFFICER  
(Assistant Engineer / Assistant Executive Engineer)

Name of School Olive public School Perambra

1. Name of the Officer SOORAJ. P. G  
Perambra Pathth road - keshikode.
2. Location Thammaraasery - sub dt
3. Period for which the certificate is issued 2022-23
4. Types of building RCC framed structure having GF, PP, SF with two stair rooms. Separate sheet has attached for showing the class room size and height.
5. Nature of defect if any

a) Foundation and basement No defect

b) Superstructure "

c) Doors and windows "

d) Wood work wrought and put up "

e) Roof "

f) Flooring "

g) Miscellaneous (Cracks if any) No

6. Any major defects noticed which will render the building unsafe in any manner No

7. Whether maintenance work have been done properly <sup>Yes</sup>  
The structure is sound enough to conduct classes under normal wind and weather conditions. This first fitness certificate has issued based on the stability certificate issued by the govt Eng college KKD, vide file no: CCE/2541/23/12 dt: 26/5/2023.

8. Whether the structure is sound or not for conducting classes. <sup>Yes</sup>

- Note: 1 The Stability of the structure should be examined also with reference to location altitude intensity of wind exposure to flood etc.
- 2 Any additional observation deemed necessary for the Certificate, may be furnished separately with the Certificate.

Certified that the School was inspected by me on 30/6/2023 and found to be, fit / unfit to conduct classes for the period for the reasons stated above.

Place: Perambra

Date: 30/6/2023



Signature

Designation

Assistant Executive Engineer  
LID & EW Sub Division  
Perambra, Kozhikode